

Message

---

**From:** Brett Gleitsmann [bgleitsmann@rcac.org]  
**Sent:** 6/7/2019 6:05:16 PM  
**To:** Tsai, Yun-Jui [Tsai.Yun-Jui@epa.gov]  
**CC:** Greenberg, Leslie [Greenberg.Leslie@epa.gov]; Rapicavoli, Emmanuelle [Rapicavoli.Emmanuelle@epa.gov]  
**Subject:** Hopi call - summary

Hi Jeffrey,

Here is a summary of our Hopi call from today:

Second Mesa Day School – The operator is planning to email EPA confirming that their budget for the pH control was approved. Next step will be to transfer the funds and contact APE (contractor) to schedule the install.

BIA Keams – The contract was not updated to include pH control or PLC update as far as Scott knows. Brett will follow up with Melvin Todacheene next week to see about that and this and the preventative maintenance program. EPA may follow up with John Graves or John Krause as well.

Mishongnovi – The chlorinator is not installed yet. As of last week the operator still was missing a saddle for the install. Brett will follow up next week with Wilson to see if he got it installed.

HVMC – No progress as the slab has not been poured yet. Brett will follow up with Phil and Edgar next week to see when it will be completed. EPA will need to establish a deadline for this to be completed, tentatively August 31st.

HCC – Enforcement will be there on 6/26 and Brett will remind Phil and Edgar next week that they need to make as much progress as possible before that visit. Also, there should be a PN for having not resolved their significant deficiencies on time. Brett can make sure they received the PN template and have distributed it.

Lower Moenkopi – The screen mesh size on the overflow is too big and they need to install a #12 screen. Brett will check on this next week with Earl. As for the spring box and chlorinator, these were to be addressed by IHS but Brett has not heard any updates.

Hopi HS – SOP for Well #1 was completed but Brett will add a line for sending WQ results to datamanager@epa.gov. Chuck did run Well #1 in May to sample for arsenic but results are not yet received by EPA. Brett will follow up with Chuck next week to make sure he sent results in to datamanager@epa.gov. Also make sure that Chuck sampled for nitrate, arsenic and the inorganics for Well #1. Brett will also find out if he is logging daily chlorine residual and that it is 0.2 ppm or higher.

Upper Moenkopi – The good news is that the \$200,000 budget was approved and Ky has sent an email to EPA on this. They are still trying to hire a GM but have not had any luck.

Other update is that Selwyn's last day is today at Kykotsmovi. He was hired by IHS as a construction supervisor based out of Polacca (the same job that Gina Yellowhair has). Dean will be the interim lead operator but the village has advertised to try to fill Selwyn's spot.

Thanks,  
Brett

**Brett Gleitsmann**  
**RCAC | Environmental**  
Rural Development Specialist | Arizona  
(928) 864-7597

